


TEMPEST PLUGGABLE FILTER – DS30835 NSN 5915-99-402-0482





Typical insertion loss in a 50Ω system, measured in accordance with CISPR 17, with or without load

DESCRIPTION

- TEMPEST EMI SP & N / 2 Phase Filter providing performance to SDIP-27 B/C
- Insertion loss of 60dB from 100kHz to 1GHz
- Designed for rapid deployment applications where hardwired connections are not practical
- Quad UK Standard BS1363 3-pin output socket
- UK Standard BS1363 3-pin input plug with standard BS1362 13A replaceable fuse
- Designed to IT equipment safety standard EN 60950-1
- Fully 360° screened input cable to maintain red/black separation to filter
- Low Smoke Zero Halogen (LSZH) rated cabling for use in sensitive areas
- Self-healing metallised plastic film capacitor dielectric for fail-safe transient handling
- Rugged Stainless Steel enclosure
- Design of filter is downline tolerable to a personnel protection RCCB
- CE and RoHS Compliant

RATINGS AND CHARACTERISTICS

Part Number

NATO Stock Number

Number of Lines

Rated Voltage

Test Voltage (line – earth)

Test Voltage (line – line)

Rated Current, IR at 50°C

Maximum Earth Leakage Current

Maximum Temperature Rise on Full Load

Operating Temperature Range

Insertion Loss (50Ω , asymmetric)

Discharge Time

DS30835

5915-99-402-0482

2 (Single Phase and Neutral or 2 Phase)

250Vac 50/60Hz

2250Vdc

1250Vdc

13A

3.5mA

25°C

-25°C to 50°C


60dB from 100kHz to 1GHz (see graph)


Less than 1s to below 34V



TEMPEST PLUGGABLE FILTER - DS30835 NSN 5915-99-402-0482

DIMENSIONS AND MECHANICAL DETAILS (All dimensions in mm)





Ferromagnetic Stainless Steel

Epoxy resin meeting UL94-V0

Via input termination earth pin

4 x BS1363 3-pin socket

Enclosure

Capacitor Potting **Output Termination**

Fusing

Mounting

Weight (approx.)

Finish

Marking

Input Termination Earth Connection

13A BS1362 fuse within input plug 4 x φ 6mm holes 4.0kg

Natural, brushed.

Self-adhesive label (see outline drawing for details)

BS1363 3-pin leading earth plug on 2m flexible screened LSZH cable

INSTALLATION

Although the filter does not need to be mounted to a solid surface, it is provided with a mounting option and were possible it should be fixed securely with maximum distance between the filter and the User's device. The Input screened cable and the User's Output cables should be maximally separated from each other to maintain red/black cable separation. Please see the MPE TEMPEST Pluggable Filters Installation and Maintenance Guide Application Note for further information.

SAFETY

Relevant safety standards have been adhered to in the design and manufacture of this product. The filter must be solidly and permanently earthed to allow safe discharge of all internal capacitors - The earth connection of the input plug must be present and must not be interfered with. The User should ensure they do not overload the filter over the 13A load limit.