


TEMPEST PLUGGABLE FILTER - DS30836 NSN 5915-99-845-4710





Typical insertion loss in a 50Ω system, measured in accordance with CISPR 17, with or without load

DESCRIPTION

- TEMPEST EMI SP & N / 2 Phase Filter providing performance to SDIP-27 B/C
- Insertion loss of 60dB from 100kHz to 1GHz
- Designed for rapid deployment applications where hardwired connections are not practical
- Flying lead screened output for customer termination
- UK Standard BS1363 3-pin input plug with standard BS1362 13A replaceable fuse
- Designed to IT equipment safety standard EN 60950-1
- Fully 360° screened input cable to maintain red/black separation to filter
- Low Smoke Zero Halogen (LSZH) rated cabling for use in sensitive areas
- Self-healing metallised plastic film capacitor dielectric for fail-safe transient handling
- **Rugged Stainless Steel enclosure**
- Design of filter is downline tolerable to a personnel protection RCCB
- **CE and RoHS Compliant**

RATINGS AND CHARACTERISTICS

Maximum Earth Leakage Current

Part Number DS30836

NATO Stock Number 5915-99-845-4710

Number of Lines 2 (Single Phase and Neutral or 2 Phase)

Rated Voltage 250Vac 50/60Hz

Test Voltage (line – earth) 2250Vdc Test Voltage (line – line) 1250Vdc Rated Current, IR at 50°C 13A

Maximum Temperature Rise on Full Load 25°C

Operating Temperature Range Insertion Loss (50Ω , asymmetric)

Discharge Time

-25°C to 50°C

3.5mA


60dB from 100kHz to 1GHz (see graph)

Less than 1s to below 34V



TEMPEST PLUGGABLE FILTER – DS30836 NSN 5915-99-845-4710

DIMENSIONS AND MECHANICAL DETAILS (All dimensions in mm)





Enclosure Ferromagnetic Stainless Steel
Capacitor Potting Epoxy resin meeting UL94-V0

Unterminated 2m flexible screened LSZH cable

BS1363 3-pin leading earth plug on 2m flexible screened LSZH cable

Via input termination earth pin
13A BS1362 fuse within input plug

4 x φ 6mm holes

Weight (approx.) 3.0kg

Finish Natural, brushed

Marking Self-adhesive label (see outline drawing for details)

INSTALLATION

Output Termination

Input Termination

Earth Connection

Fusing

Mounting

Although the filter does not need to be mounted to a solid surface, it is provided with a mounting option and were possible it should be fixed securely with maximum distance between the filter and the User's device. The Input and Output screened cables should be maximally separated from each other to maintain red/black cable separation. Please see the MPE TEMPEST Pluggable Filters Installation and Maintenance Guide Application Note for further information.

SAFETY

Relevant safety standards have been adhered to in the design and manufacture of this product. The filter must be solidly and permanently earthed to allow safe discharge of all internal capacitors - The earth connection of the input plug must be present and must not be interfered with. The User should ensure they do not overload the filter over the 13A load limit.