


BS1363 TEMPEST EMI FILTER – DS30839 NSN 5915-99-615-9661





Typical insertion loss in a 50Ω system, measured in accordance with CISPR 17, with or without load

DESCRIPTION

- TEMPEST EMI SP & N / 2 Phase Filter providing performance to SDIP-27 B/C
- Insertion loss of 60dB from 100kHz to 1GHz
- Designed for rapid deployment applications where hardwired connections are not practical
- Flying lead screened output for customer termination
- Industry Standard IEC 60309 2P+E 32A IP44 'Commando' input connector
- Designed to IT equipment safety standard EN 60950-1
- Fully 360° screened input cable to maintain red/black separation to filter
- Low Smoke Zero Halogen (LSZH) rated cabling for use in sensitive areas
- Self-healing metallised plastic film capacitor dielectric for fail-safe transient handling
- Rugged Stainless Steel enclosure
- Design of filter is downline tolerable to a personnel protection RCCB
- CE and RoHS Compliant

RATINGS AND CHARACTERISTICS


Part Number NATO Stock Number Number of Lines Rated Voltage Test Voltage (line – earth) Test Voltage (line – line) Rated Current, I_R at 50°C Maximum Earth Leakage Current Maximum Temperature Rise on Full Load Operating Temperature Range Insertion Loss (50 Ω , asymmetric) Discharge Time

DS30839 5915-99-615-9661 2 (Single Phase and Neutral or 2 Phase) 250Vac 50/60Hz 2250Vdc 1250Vdc 32A 20mA 25°C -25°C to 50°C 60dB from 100kHz to 1GHz (see graph) Less than 1s to below 34V



BS1363 TEMPEST EMI FILTER – DS30839 NSN 5915-99-615-9661

DIMENSIONS AND MECHANICAL DETAILS (All dimensions in mm)



Capacitor Potting **Output Termination** Unterminated 2m flexible screened LSZH cable IEC 60309 2P+E 32A IP44 'Commando' plug on 2m flexible screened LSZH cable Input Termination Earth Connection Via input termination earth pin No fusing within filter unit. The User must ensure adequate fusing Fusing Mounting 4 x φ 6mm holes Weight (approx.) 10.0kg Finish Natural, brushed Marking Self-adhesive label (see outline drawing for details)

INSTALLATION

Although the filter does not need to be mounted to a solid surface, it is provided with a mounting option and were possible it should be fixed securely with maximum distance between the filter and the User's device. The Input and Output screened cables should be maximally separated from each other to maintain red/black cable separation. Please see the MPE TEMPEST Pluggable Filters Installation and Maintenance Guide Application Note for further information.

SAFETY

Relevant safety standards have been adhered to in the design and manufacture of this product. The filter must be solidly and permanently earthed to allow safe discharge of all internal capacitors - The earth connection of the input plug must be present and must not be interfered with. The User should ensure they do not overload the filter over the 32A load limit.